

Matt Wardynski
 ENGR 115
 2:00-5:00pm
 10/20/2016


Input Parameters	
Outdoor CO ₂ , ppm	388
Assumed CO ₂ , ppm	400
Correction Factor, ppm	12
Volume of Room, ft ³	1287
Room Capacity, ppl	2

Mason and Pedro's Dorm Room Analysis

Minutes	Date Time, GMT-07:00	Hobo CO ₂ , ppm	Actual CO ₂ , ppm
1	10/20/2016 14:46	799.8	811.8
2	10/20/2016 14:47	634.9	646.9
3	10/20/2016 14:48	459.1	471.1
4	10/20/2016 14:49	398.7	410.7
5	10/20/2016 14:50	406.6	418.6
6	10/20/2016 14:51	398.7	410.7
7	10/20/2016 14:52	393.8	405.8
8	10/20/2016 14:53	386.4	398.4
9	10/20/2016 14:54	818.1	830.1
10	10/20/2016 14:55	710	722
11	10/20/2016 14:56	740.5	752.5
12	10/20/2016 14:57	734.4	746.4
13	10/20/2016 14:58	771.7	783.7
14	10/20/2016 14:59	812.6	824.6
15	10/20/2016 15:00	884	896
16	10/20/2016 15:01	950.5	962.5
17	10/20/2016 15:02	1102.6	1114.6
18	10/20/2016 15:03	1105.6	1117.6
19	10/20/2016 15:04	1129.4	1141.4
20	10/20/2016 15:05	1179.5	1191.5
21	10/20/2016 15:06	1219.8	1231.8
22	10/20/2016 15:07	1239.9	1251.9
23	10/20/2016 15:08	1278.4	1290.4
24	10/20/2016 15:09	1299.8	1311.8
25	10/20/2016 15:10	1366.3	1378.3
26	10/20/2016 15:11	1462.8	1474.8
27	10/20/2016 15:12	1504.3	1516.3
28	10/20/2016 15:13	1570.8	1582.8
29	10/20/2016 15:14	1611.1	1623.1
30	10/20/2016 15:15	1631.9	1643.9
31	10/20/2016 15:16	1656.9	1668.9
32	10/20/2016 15:17	1655.7	1667.7
33	10/20/2016 15:18	1653.8	1665.8
34	10/20/2016 15:19	1647.7	1659.7
35	10/20/2016 15:20	1622.7	1634.7
36	10/20/2016 15:21	1616	1628

37	10/20/2016 15:22	1611.7	1623.7
38	10/20/2016 15:23	1613.6	1625.6
39	10/20/2016 15:24	1602	1614
40	10/20/2016 15:25	1578.1	1590.1
41	10/20/2016 15:26	1565.9	1577.9
42	10/20/2016 15:27	1586.1	1598.1
43	10/20/2016 15:28	1582.4	1594.4
44	10/20/2016 15:29	1579.4	1591.4
45	10/20/2016 15:30	1591	1603
46	10/20/2016 15:31	1594.6	1606.6
47	10/20/2016 15:32	1581.2	1593.2
48	10/20/2016 15:33	1586.7	1598.7
49	10/20/2016 15:34	1590.4	1602.4
50	10/20/2016 15:35	1592.2	1604.2
51	10/20/2016 15:36	1594.6	1606.6
52	10/20/2016 15:37	1603.2	1615.2
53	10/20/2016 15:38	1599.5	1611.5
54	10/20/2016 15:39	1591.6	1603.6
55	10/20/2016 15:40	1553.1	1565.1
56	10/20/2016 15:41	1565.9	1577.9
57	10/20/2016 15:42	1565.9	1577.9
58	10/20/2016 15:43	1561.7	1573.7
59	10/20/2016 15:44	1562.9	1574.9
60	10/20/2016 15:45	1551.3	1563.3
61	10/20/2016 15:46	1500	1512
62	10/20/2016 15:47	1500.6	1512.6
63	10/20/2016 15:48	1503.1	1515.1
64	10/20/2016 15:49	1496.9	1508.9
65	10/20/2016 15:50	1106.2	1118.2
66	10/20/2016 15:51	494.5	506.5
67	10/20/2016 15:52	420	432
68	10/20/2016 15:53	441.4	453.4
69	10/20/2016 15:54	437.1	449.1
70	10/20/2016 15:55	426.7	438.7
71	10/20/2016 15:56	401.7	413.7
72	10/20/2016 15:57	418.2	430.2
73	10/20/2016 15:58	556.2	568.2
74	10/20/2016 15:59	523.2	535.2
75	10/20/2016 15:59		
76	10/20/2016 15:59		

Actual Concentration Plot




Ventilation Rate Analysis

Date and Time	Minutes	Hours	CO ₂ , ppm	Y-axis
10/20/2016 15:16	0	0.000	1669	0
10/20/2016 15:17	1	0.017	1668	0.0009461
10/20/2016 15:18	2	0.033	1666	0.0024461
10/20/2016 15:19	3	0.050	1660	0.0072768
10/20/2016 15:20	4	0.067	1635	0.0273224
10/20/2016 15:21	5	0.083	1628	0.0327636
10/20/2016 15:22	6	0.100	1624	0.0362713
10/20/2016 15:23	7	0.117	1626	0.0347199
10/20/2016 15:24	8	0.133	1614	0.0442297
10/20/2016 15:25	9	0.150	1590	0.0641130
10/20/2016 15:26	10	0.167	1578	0.0744172
10/20/2016 15:27	11	0.183	1598	0.0574134
10/20/2016 15:28	12	0.200	1594	0.0605064
10/20/2016 15:29	13	0.217	1591	0.0630213
10/20/2016 15:30	14	0.233	1603	0.0533319
10/20/2016 15:31	15	0.250	1607	0.0503439
10/20/2016 15:32	16	0.267	1593	0.0615116
10/20/2016 15:33	17	0.283	1599	0.0569127
10/20/2016 15:34	18	0.300	1602	0.0538308
10/20/2016 15:35	19	0.317	1604	0.0523349
10/20/2016 15:36	20	0.333	1607	0.0503439
10/20/2016 15:37	21	0.350	1615	0.0432417
10/20/2016 15:38	22	0.367	1612	0.0462911
10/20/2016 15:39	23	0.383	1604	0.0528333
10/20/2016 15:40	24	0.400	1565	0.0853435
10/20/2016 15:41	25	0.417	1578	0.0744172
10/20/2016 15:42	26	0.433	1578	0.0744172
10/20/2016 15:43	27	0.450	1574	0.0779892
10/20/2016 15:44	28	0.467	1575	0.0769673
10/20/2016 15:45	29	0.483	1563	0.0868896
10/20/2016 15:46	30	0.500	1512	0.1319902
10/20/2016 15:47	31	0.517	1513	0.1314508
10/20/2016 15:48	32	0.533	1515	0.1292063
10/20/2016 15:49	33	0.550	1509	0.1347819

Input Parameters	
Outdoor CO ₂ , ppm	388
Assumed CO ₂ , ppm	400
Correction Factor, ppm	12
Volume of Room, ft ³	1287
Room Capacity, ppl	2

Ventilation Rate Analysis for Mason and Pedro's Dorm Room



1. What is the air exchange rate (λ) of the room you tested? Be sure to include the units for the air exchange rate in your answer.

The exchange rate was 0.2079 hr^{-1}

2. In general it takes $3/\lambda$ hours to remove a non-reactive chemical from indoor air. Based on this time, what recommendations would you make to the occupants of the room?

My value for $3/\lambda$ is about 14 hours. Because of the poor ventilation, it will take a long time for the non-reactive chemical to be removed, so I would recommend that the occupants of the room should either open as many windows as possible, or just get out of the room.

3. Compare your ventilation rate for a typical number of occupants to the ASHRAE recommended ventilation rate. Based on this comparison, are the occupants wasting energy heating and cooling the air or are the occupants being too cheap and not supplying enough air? Justify your answer.

My ventilation rate is 2.2 scfm/person while the ASHRAE recommended ventilation rate is about 15 scfm/person. That is a problem. The room occupants are being too cheap by not supplying enough air because the ventilation rate is much lower than the ASHRAE recommended ventilation rate. If they were trying to heat the room, they would have no trouble getting it warm because of the poor ventilation. Therefore, they are saving money on heating, but at the cost of poor indoor air quality.

4. Given the ASHRAE standard ventilation standard, what is the maximum number of people you would recommend having in this room at one time? Use your model to determine this number.

If there was 0.3 people in the room, then there would be a ventilation rate of 14.9 scfm/person. However, it isn't really possible to have a third of a person living in a dorm room, so that's not good.

Input Parameters

Outdoor CO_2 , ppm	388
Assumed CO_2 , ppm	400
Correction Factor, ppm	12
Volume of Room, ft^3	1287
Room Capacity, ppl	0.3

Calculations

Air Exchange Rate, 1/hr	0.2079
Time to remove non-reactive chemical, hr	14
Ventilation Rate, $\text{ft}^3/\text{min}/\text{person}$	15